

# 2019 Consumer Confidence Report for Public Water System CHAMBERS MEADOW ESTATE WATER

This is your water quality report for January 1 to December 31, 2019

For more information regarding this report contact:

CHAMBERS MEADOW ESTATE WATER provides ground water from the Woodbine Aquifer located in **Ellis County**.

Name: Tommy Bradley

Phone: (800)338-6425 Ext: 3315

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (800)338-6425-Ext: 1151.

## Definitions and Abbreviations

Definitions and Abbreviations	The following tables contain scientific terms and measures, some of which may require explanation.
Action Level:	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG):	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
mrem:	millirems per year (a measure of radiation absorbed by the body)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion – or one ounce in 7,350,000 gallons of water.
Ppm:	milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.
Ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

## Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

'This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 milligrams per liter (mg/L) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by your community water system **CHAMBERS MEADOW ESTATE WATER SYSTEM** has a fluoride concentration of **3.09 mg/L.**'

'Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water.'

'For more information, please call **TOMMY BRADLEY** of **CHAMBERS MEADOW ESTATE WATER SYSTEM** at (800)338-6425 ext. 3315. Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at 1-877-8-NSF-HELP.

**PUBLIC PARTICIPATION OPPORTUNITY**

Date: August 6, 2020

Time: 9:00 am

Location: HILCO Electric Cooperative, Inc., 115 E Main St, Itasca, TX

To learn about future public meetings (concerning your drinking water), or request to schedule one, please call us.

**Information about Source Water**

CHAMBERS MEADOW ESTATE WATER provides ground water from the Woodbine Aquifer located in **Ellis County**.

Water System Detail Information						
Water System No.:	TX0700071			Federal Type:	C	
Water System Name:	CHAMBERS MEADOW ESTATE WATER			Federal Source:	GW	
Principal County Served:	ELLIS			System Status:	A	
Principal City Served:				Activity Date:	01-01-1913	
PBCU Sample Summary Results						
MP Begin Date	Type	# Samples	Measure	Units	Analyte Code/Name	Last Sample Date
<a href="#">01-01-2015</a> <a href="#">12-31-2017</a>	90%	5	0.064	MG/L	CU90 – COPPER SUMMARY	09-14-2017
<a href="#">01-01-2015</a> <a href="#">12-31-2017</a>	AL	0 Exceeding Action Level			CU90 – COPPER SUMMARY	
<a href="#">01-01-2015</a> <a href="#">12-31-2017</a>	AL	0 Exceeding Action Level			PB90 – LEAD SUMMARY	
<a href="#">01-01-2015</a>	90%	5	0.0007	MG/L	PB90 – LEAD SUMMARY	09-14-2017

12-31-2017						
<a href="#">01-01-2012</a> 12-31-2014	AL	0 Exceeding Action Level			CU90 – COPPER SUMMARY	
<a href="#">01-01-2012</a> 12-31-2014	90%	5	0.076	MG/L	CU90 – COPPER SUMMARY	09-14-2014
<a href="#">01-01-2012</a> 12-31-2014	90%	5	0	MG/L	PB90 – LEAD SUMMARY	09-14-2014
<a href="#">01-01-2012</a> 12-31-2014	AL	0 Exceeding Action Level			PB90 – LEAD SUMMARY	
<a href="#">01-01-2001</a> 12-31-2009	90%	5	0.0053	MG/L	CU90 – COPPER SUMMARY	06-11-2009
<a href="#">01-01-2001</a> 12-31-2009	AL	0 Exceeding Action Level			CU90 – COPPER SUMMARY	
<a href="#">01-01-2001</a> 12-31-2009	AL	0 Exceeding Action Level			PB90 – LEAD SUMMARY	
<a href="#">01-01-2001</a> 12-31-2009	90%	5	0.000259	MG/L	PB90 – LEAD SUMMARY	06-11-2009

\*TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact TOMMY BRADLEY at (800)338-3-6425.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 <sup>th</sup> Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/14/2017	1.3	1.3	0.064	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09/14/2017	0	15	0.7	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

## 2019 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2019	6.1	6.1 – 6.1	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

<b>Total Trihalomethanes (TTHM)</b>	2019	29.4	29.4 – 29.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
-------------------------------------	------	------	-------------	-----------------------	----	-----	---	--

<b>Inorganic Contaminants</b>	<b>Collection Date</b>	<b>Highest Level Detected</b>	<b>Range of Individual Samples</b>	<b>MCLG</b>	<b>MCL</b>	<b>Units</b>	<b>Violation</b>	<b>Likely Source of Contamination</b>
<b>Barium</b>	2019	0.0079	0.0079 – 0.0079	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
<b>Chromium</b>	2019	1.2	1.2 – 1.2	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
<b>Cyanide</b>	09/18/2017	109	109 – 109	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
<b>Fluoride</b>	2019	3.09	3.09 – 3.09	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
<b>Nitrate [measured as Nitrogen]</b>	2019	0.105	0.105 – 0.105	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

#### **Disinfectant Residual**

<b>Disinfectant Residual</b>	<b>Year</b>	<b>Average Level</b>	<b>Range of Levels Detected</b>	<b>MRDL</b>	<b>MRDLG</b>	<b>Unit of Measure</b>	<b>Violation (Y/N)</b>	<b>Source in Drinking Water</b>
Chloramines	2019	1.78	1.1 – 2.7	4	4	mg/L	N	Water additive used to control microbes.

