



## **FIREFIGHTING RESCUE FORCE of MORAVIAN-SLIEZIAN REGION**

70030 Ostrava – Záběh, Výškovocká 40

Your letter mark:  
From date: 30.7.2015  
Our mark:

PROTENG DISTRIBUTION CZ  
ID.No.: 03875377  
V dolině 1515/b  
Michle  
10100 Praha 10

Attendant: kpt.Eng.Martin Nekula  
Phone: +420 950 730 193  
e-mail: [martin.nekula@hzmsk.cz](mailto:martin.nekula@hzmsk.cz)

Date: 1<sup>st</sup> of October 2015

No. of pages: 1  
Attachments: 0

Object: Standpoint to testing assistance of an Automatic extinguishing system product

Firefighting Rescue Force (FRF) of Moravian-Silesian region puts under practical testing Automatic extinguishing systems. Tests was made by following demand of company PROTENG DISTRIBUTION CZ Ltd. The examination process consists in real verification of functionality and general usability of Proteng products that were trial on burning personal car, and further on electrical distribution box and on PC.

There were also asked to assists employees of Department of Fire Protection - Faculty of Safety Engineering of the High school of Mine - Technical University in Ostrava, who made measurements of temperatures during automatic extinguishing of fire of the products mentioned above.

During examination was verified extinguishing ability of Proteng products where fire inside of personal car was extinguished automatically. Further was extinguished by form of volume quenching also electrical distribution box and PC, both placed in enclosed areas.

We can state, that mentioned products fulfill declared extinguishing abilities throughout real examination.

With kind regards

plk.Eng. Jan Bojko  
Chief of Service Department  
FRF of Moravian-Silesian region

Phone: +420 950 730 011

ID.No.: 70884561

Fax: +420 596750937